

## Legislation Details (With Text)

---

**File #:** 220299      **Version:** 0      **Name:**

**Type:** Bill      **Status:** IN COMMITTEE

**File created:** 3/31/2022      **In control:** Committee on Licenses and Inspections

**On agenda:**      **Final action:**

**Title:** Amending Subcode "F" of Title 4 of The Philadelphia Code, entitled "The Philadelphia Fire Code," to require the installation of automatic fire sprinkler systems in additional high-rise buildings, all under certain terms and conditions.

**Sponsors:** Councilmember Squilla, Councilmember Gilmore Richardson

**Indexes:** FIRE CODE

**Code sections:**

**Attachments:** 1. Bill No. 22029900.pdf

Date	Ver.	Action By	Action	Result	Tally
3/31/2022	0	CITY COUNCIL	Introduced and Referred		

Amending Subcode "F" of Title 4 of The Philadelphia Code, entitled "The Philadelphia Fire Code," to require the installation of automatic fire sprinkler systems in additional high-rise buildings, all under certain terms and conditions.

*THE COUNCIL OF THE CITY OF PHILADELPHIA HEREBY ORDAINS:*

SECTION 1. Title 4 of The Philadelphia Code is amended as follows:

TITLE 4. THE PHILADELPHIA BUILDING CONSTRUCTION AND OCCUPANCY CODE

SUBCODE "F" (THE PHILADELPHIA FIRE CODE)

CHAPTER 11.

CONSTRUCTION REQUIREMENTS FOR EXISTING BUILDINGS

SECTION 1103 FIRE SAFETY REQUIREMENTS FOR EXISTING BUILDINGS

\* \* \*

Add Sections F-1103.5.5 through F-1103.5.8.2 as follows:

\* \* \*

F-1103.5.6 High-rise buildings. An automatic sprinkler system shall be installed throughout existing high-rise buildings.

[Exception: Portions of high-rise buildings occupied by Group R-2 occupancies without a change in occupancy since December 18, 1991.]

[F-1103.5.6.1 High-rise Group R-2 occupancies. An automatic sprinkler system shall be installed in the following areas of existing Group R-2 occupancies in the portions of the high-rise building to which the requirements of Section F-1103.5.6 do not apply:

1. Basements in accordance with Section F-1103.5.7.
2. Rooms used for storage where the floor area exceeds 120 square feet (11 m<sup>2</sup>).
3. Trash and incinerator chutes and rooms in accordance with F-1103.4.9.]

F-1103.5.8.2 Retrofit schedule. Proof of compliance with the automatic sprinkler system installation requirements of this Section shall be submitted to the Department of Licenses and Inspections in the form of a certification pursuant to Section 901. The required certification shall be submitted prior to January 1, 2022, *provided that for portions of high-rise buildings containing Group R-2 occupancies, with respect to which an exemption under Section F-1103.5.6 applied on March 1, 2022, but which exception has been rescinded, the installation of automatic sprinkler systems shall be completed by \_\_\_\_\_, and the required*

*certification shall be submitted prior to \_\_\_\_\_.*

SECTION 2. This Ordinance shall be effective immediately.